

# AMBUSH

## Condensate Drain Pan Treatment

**Form:** Liquid

**Color:** Blue Liquid

**Odor:** No Data Available

**pH:** 5.5-7

**Solubility (in water):** No Data Available

**(in mineral spirits):** No Data Available

**VOC Content:** < 0.1%

**Flash Point (ASTM D-7821):** > 200 °F

**Specific Gravity:** 0.995 g/ml

**Storage Stability (at 70°F):** 1 year

<b>Feature</b>
• <b>Continuous Feeding</b>
• <b>Rapid Bottle Change Out</b>
• <b>Battery Operated</b>
• <b>Works Indoors and Outdoors</b>
• <b>Works In Any Commercial AC Unit</b>

**Ingredients**

	<b><u>C.A.S. #</u></b>
Water	7732-18-5
Alcohol Ethoxylate	68439-46-3
Alkyl (68% C <sub>12</sub> , 32% C <sub>14</sub> ) dimethyl ethylbenyl ammonium chloride	85409-23-0
Alkyl dimethyl benzyl ammonium chloride (C <sub>12</sub> -C <sub>18</sub> )	69391-01-5
Ethanol	64-17-5

**DIRECTIONS:** Load refill bottle at a 45 degree angle to the dispenser unit and insert plastic tipoff refill bottle into receptor hole of actuator. Swivel the bottom of the refill down and back toward dispenser until it clicks firmly. Set dispenser unit to desired interval (7.5min, 15 min or 30 min) and ensure power is on.

**CONSULT PRODUCT LABEL FOR DETAILED USE DIRECTIONS.**

<b>HMIS</b>		<b>NFPA</b>
	Severe 4 Extreme	
Health .....2	Serious 3 High	Health ..... 2
Flammability.....2	Moderate 2 Moderate	Flammability ..... 2
Reactivity.....0	Slight 1 Slight	Reactivity..... 0